ADDENDUM NO. TWO (2)

Project:	Harold D. Thompson Regional Water Reclamatic Phase 1 – 2.5 MGD	on Facility
Date of Addendum:	March 15, 2011	
Owner:	Lower Fountain Metropolitan Sewage Disposal District	
Engineer:	GMS, Inc. 611 North Weber, Suite 300 Colorado Springs, CO 80903	Phone: (719) 475-2935 Telefax: (719) 475-2938

THE FOLLOWING REVISIONS AND CLARIFICATIONS ARE HEREBY MADE TO THE BIDDING AND CONTRACT DOCUMENTS FOR THIS PROJECT:

PART I – GENERAL

1.01 SCOPE

- A. This Addendum forms a part of the Contract Documents and modifies the Project Manual and Drawings as described below.
- B. This Addendum consists of two (2) pages, including attachments.
- 1.02 ACKNOWLEDGMENT
 - A. Acknowledge receipt of this Addendum by return electronic mail correspondence.

PART II - PROJECT MANUAL

- 2.01 BIDDING REQUIREMENTS This Addendum No. Two (2) makes no changes to the Bidding Requirements
- 2.02 TECHNICAL SPECIFICATIONS
 - A. Section 11331 Screening Equipment:
 - 1. **DELETE** Paragraph 2.4.D.5. in its entirety and renumber subsequent paragraphs 6., 7. and 8. accordingly.
 - 2. **ADD** new Paragraphs 2.4.D.6.a. and 2.4.D.6.b. to read as follows:
 - "a. Local stop pushbutton will serve as local disconnect switch
 - b. Provide stop pushbutton with locking hasp or cover for equipment lockout"
 - B. Section 11314 Recessed Impeller Pumps:
 - 1. **DELETE** Paragraph 2.6.E. in its entirety and renumber subsequent paragraphs F. and G. accordingly.

- 2. **REVISE** renumbered Paragraph 2.6.E. to read as follows:
 - "E. Provide a local emergency stop pushbutton at each grit pump in a NEMA 7 enclosure
 - 1. Local stop pushbutton will serve as local disconnect switch
 - 2. Provide stop pushbutton with locking hasp or cover for equipment lockout"

PART III - DRAWINGS - This Addendum No. Two (2) makes no changes to the Drawings

THIS ADDENDUM IS HEREBY MADE A PART OF THE BIDDING AND CONTRACT DOCUMENTS FOR THIS PROJECT AND IS BINDING AS IF PRINTED AND BOUND THEREIN. ALL BIDDERS SHALL ACKNOWLEDGE RECEIPT OF THIS ADDENDUM IN THE APPROPRIATE LOCATION ON THE BID FORM.

END OF ADDENDUM NO. TWO (2)