

**ADDENDUM NO. THREE (3)**

**Project:** Harold D. Thompson Regional Water Reclamation Facility  
Phase 1 – 2.5 MGD

**Date of Addendum:** March 24, 2011

**Owner:** Lower Fountain Metropolitan Sewage Disposal District

**Engineer:** GMS, Inc. Phone: (719) 475-2935  
611 North Weber, Suite 300 Telefax: (719) 475-2938  
Colorado Springs, CO 80903

THE FOLLOWING REVISIONS AND CLARIFICATIONS ARE HEREBY MADE TO THE BIDDING AND CONTRACT DOCUMENTS FOR THIS PROJECT:

**PART I – GENERAL**

1.01 SCOPE

- A. This Addendum forms a part of the Contract Documents and modifies the Project Manual and Drawings as described below.
- B. This Addendum consists of two (2) pages.

1.02 ACKNOWLEDGMENT

- A. Acknowledge receipt of this Addendum by return electronic mail correspondence.

**PART II - PROJECT MANUAL**

2.01 BIDDING REQUIREMENTS – This Addendum No. Three (3) makes no changes to the Bidding Requirements

2.02 TECHNICAL SPECIFICATIONS

- A. Section 02200 - Earthwork
  - 1. **REVISE** Paragraph 2.1.F.1.c.1) to read as follows:

"1) Required gradation

<u>Sieve Size</u>	<u>Percent Passing by Weight Square Mesh Sieves</u>
2"	100
No. 4	30-100
No. 50	10-60
No. 200	5-20

In addition, this material shall have a liquid limit not exceeding 35 and a plasticity index less than six (6) when determined in conformity with AASHTO T89 and T90, respectively"

B. Section 14555 – Shaftless Screw Conveyors:

1. **REVISE** Paragraph 2.3.B.7.a. to read as follows:

"a. Conveyor CV-1

- 1) Skirt boards required at receiving end of trough only
- 2) Extend minimum 2'-6" above top of trough
- 3) At receiving end of trough, place skirt boards on each side and end of trough
  - a) Across active width of trough at receiving end
  - b) Minimum 4'-0" long on side opposite feed pipes"

2. **ADD** new Paragraph 2.3.B.7.a.3)c) to read as follows:

"c) Between screenings discharge or feed pipes"

PART III – DRAWINGS – This Addendum No. Three (3) makes no changes to the Drawings

THIS ADDENDUM IS HEREBY MADE A PART OF THE BIDDING AND CONTRACT DOCUMENTS FOR THIS PROJECT AND IS BINDING AS IF PRINTED AND BOUND THEREIN. ALL BIDDERS SHALL ACKNOWLEDGE RECEIPT OF THIS ADDENDUM IN THE APPROPRIATE LOCATION ON THE BID FORM.

END OF ADDENDUM NO. THREE (3)