

REQUEST FOR INFORMATION

Request for Information - RFI #	16	ROUTING	DATE SENT	VIA MAIL, EMAIL OR FAX			DATE RECEIVED	VIA MAIL, EMAIL OR FAX		
				M	E	F		M	E	F
OWNER: LFMSDD		Contractor to Engineer	7/20/2011		X		7/20/2011		X	
PROJECT: HDTRWRF		Engineer to Contractor	7/27/2011		X					
ENGINEER: GMS, Inc.		Copy to Owner	7/27/2011		X					
CONTRACTOR: Weaver General Construction Co.										
RFI TITLE: DIP p-trap										
REFERENCE: 1-HW20										
CONTRACTOR'S REQUEST										
The following information, interpretation, or clarification is requested as described below or in the attachments.										
<p>*(Contractor request) Plan calls for DIP P-trap which are not made. Using 4 90 degree bends to create a P-trap is not an acceptable trap per PPRBD plumbing inspector. Epoxy lined traps are available in cast iron soil pipe. Please advise ASAP due to 3 week ship date.</p>										
<p>By: Jeff Burst Date: 7/20/2011</p>										
ENGINEER'S RESPONSE										
The following information, interpretation, or clarification is provided as described below or in the attachments.										
<p>An epoxy-lined cast iron soil pipe P-trap is an acceptable alternative as is epoxy-lined cast iron soil pipe in lieu of epoxy-lined ductile iron pipe.</p>										
<p>By: David R. Frisch, P.L.S. Date: July 27, 2011</p>										

cc: Wes Weaver, Jeff Burst, John Jacob, WCMI; Jim Heckman, LFMSDD; Tim Long, Charlie Edgar, Cindy Murray, FSD; Al Testa, CCMD; Roger Sams, Mark Morton, Dave Frisch, Jerry Miller, GMS, Inc.; Pat Danenberg, MWI; John Peiffer, Mike Gaines, MGA; Mark Reasinger, PECI