

# REQUEST FOR INFORMATION

Request for Information - RFI #	039	ROUTING	DATE SENT	VIA MAIL, EMAIL OR FAX			DATE RECEIVED	VIA MAIL, EMAIL OR FAX		
				M	E	F		M	E	F
OWNER: LFMSDD		Contractor to Engineer	8/13/2012		X		8/13/2012		X	
PROJECT: HDTRWRF		Engineer to Contractor	8/15/2012		X					
ENGINEER: GMS, Inc.		Copy to Owner	8/15/2012		X					
CONTRACTOR: Weaver Construction Management, Inc.										
RFI TITLE: Operations Building HVAC										
REFERENCE: Section 15190										
<b>CONTRACTOR'S REQUEST</b>										
The following information, interpretation, or clarification is requested as described below or in the attachments.										
<p>Kuck Mechanical has requested the following clarifications be provided.</p> <p>A. Exhaust grille in toilet/shower is not specified.</p> <p>B. Advise if round exhaust duct is to be acoustically lined.</p> <p>C. Are duct dimensions on plan internal or external for lined ductwork?</p>										
<p>By: John Jacob <span style="float: right;">Date: 8/13/12</span></p>										
<b>ENGINEER'S RESPONSE</b>										
The following information, interpretation, or clarification is provided as described below or in the attachments.										
<p>A. Find a nice exhaust grille. They are sold at Lowes.</p> <p>B. No.</p> <p>C. Internal.</p> <p>In keeping with the spirit in which Wes directed us at the CPM a couple of months ago, this can be taken care of at the shop submittal stage. Please proceed as directed above.</p>										
<p>By: David R. Frisch, P.L.S. <span style="float: right;">Date: August 15, 2012</span></p>										

cc: Wes Weaver, Jeff Burst, John Jacob, WCMI; Jim Heckman, LFMSDD; Tim Long, Charlie Edgar, Cindy Murray, FSD; Al Testa, CCMD; Roger Sams, Mark Morton, Dave Frisch, Jerry Miller, GMS, Inc.; Pat Danenberg, MWI; John Peiffer, Mike Gaines, MGA; Mark Reasinger, PEI