

**GMS, INC.**  
CONSULTING ENGINEERS  
611 NORTH WEBER, SUITE 300  
COLORADO SPRINGS, COLORADO 80903-1074

TELEPHONE (719) 475-2935  
TELEFAX (719) 475-2938

EDWARD D. MEYER, P.E.  
ROGER J. SAMS, P.E.  
GREGORY R. WORDEN, P.E.  
THOMAS A. McCLENNAN, P.E.

KEN L. WHITE, P.L.S.  
DAVID R. FRISCH, P.L.S.  
MARK A. MORTON, P.E.  
JASON D. MEYER, P.E.

January 29, 2013

Mr. Wes Weaver, President  
Weaver Construction Management, Inc.  
c/o Garney Construction  
7911 Shaffer Parkway  
Littleton, CO 80127

*Via Email to: [wes@weavercm.com](mailto:wes@weavercm.com)  
No Hard Copy to Follow*

Re: Harold D. Thompson Regional Water Reclamation Facility (HDTRWRF)  
Lower Fountain Metropolitan Sewage Disposal District (LFMSDD)

Dear Wes:

Reference is made to your shop submittal identified as follows:

Submittal No.:	15855-002A
Date of Submittal:	January 28, 2013
Title:	Grilles, Registers and Diffusers for EM Building
Specification Section:	15855 – Diffusers, Registers and Grilles
Manufacturer:	Titus

The referenced submittal has been stamped "**No Exception Taken**" and "**Make Corrections Noted**". Our comments are as follows:

1. We take no exception to the duct mount drum louver supply grille - Titus DL with dimensions of 9" x 6". **No Exception Taken.**
2. It appears the standard finish is proposed for use which is white. In accordance with Sheet MEM-2 for the air distribution schedule, the finish is to be aluminum which is the optional finish. **Make Corrections Noted.**

Please call if you should have any questions.

Sincerely,



David R. Frisch, P.L.S.

DRF/lme

ec (letter only):

Mr. Jim Heckman, Manager, LFMSDD, [jfmanager@lfmsdd.org](mailto:jfmanager@lfmsdd.org)  
Ms. Cindy Murray, Office Manager, Fountain Sanitation District, [fsdistrict@fsd901.org](mailto:fsdistrict@fsd901.org)  
Mr. Jeff Burst, Project Supt., Weaver Construction Management, Inc., [jeff@weavercm.com](mailto:jeff@weavercm.com)  
Mr. John Jacob, Project Mgr., Weaver Construction Management, Inc., [john@weavercm.com](mailto:john@weavercm.com)  
Mr. Adam Roeder, Weaver Construction Management, Inc., [aroeder@weavercm.com](mailto:aroeder@weavercm.com)  
Mr. Gerardo Gomez, Garney Construction, [ggomez@garney.com](mailto:ggomez@garney.com)  
Ms. Solange Huggins, Garney Construction, [shuggins@garney.com](mailto:shuggins@garney.com)

cc (letter only): Mr. Jerry Miller, Resident Project Representative, GMS, Inc.