

GMS, INC.
CONSULTING ENGINEERS
611 NORTH WEBER, SUITE 300
COLORADO SPRINGS, COLORADO 80903-1074

TELEPHONE (719) 475-2935
TELEFAX (719) 475-2938

EDWARD D. MEYER, P.E.
ROGER J. SAMS, P.E.
GREGORY R. WORDEN, P.E.
THOMAS A. McCLERNAN, P.E.

KEN L. WHITE, P.L.S.
DAVID R. FRISCH, P.L.S.
MARK A. MORTON, P.E.
JASON D. MEYER, P.E.

May 8, 2012

Mr. Wes Weaver, President
Weaver Construction Management, Inc.
3679 South Huron Street, Suite 404
Englewood, CO 80110

*Via Email to: wes@weavercm.com
No Hard Copy to Follow*

Re: Harold D. Thompson Regional Water Reclamation Facility (HDTRWRF)
Lower Fountain Metropolitan Sewage Disposal District (LFMSDD)

Dear Wes:

Reference is made to your shop submittal identified as follows:

Submittal No.:	16231-001A
Date of Submittal:	May 1, 2012
Title:	600 kW & 1250 kW Generator Sets with 800 Amp & 2000 Amp ATSS
Specification Section:	16231 – Packaged Engine Generators
Manufacturer:	Cummins Rocky Mountain, Power Generation Division

The referenced submittal has been stamped "**No Exception Taken**". We acknowledge receipt of Cummins Rocky Mountain comments dated April 27, 2012. We provide the following in regard to the review comments.

1. Comment 1.b.)1.): Acceptable; however, note that the emergency stop switch will be surface mounted, not flush mounted.
2. Comment 3.b.)1.): Acceptable; however, note that the emergency stop switch will be surface mounted, not flush mounted.

Please call if you should have any questions.

Sincerely,



David R. Frisch, P.L.S.

DRF/kmw

ec (letter only):

Mr. Jim Heckman, Manager, LFMSDD, lfmanager@lfmsdd.org
Ms. Cindy Murray, Office Manager, Fountain Sanitation District, fsdistrict@fsd901.org
Mr. Jeff Burst, Project Supt., Weaver Construction Management, Inc., jeff@weavercm.com
Mr. John Jacob, Project Mgr., Weaver Construction Management, Inc., john@weavercm.com
Mr. Tyler Ammerman, Weaver Construction Management, Inc., tammerman@weavercm.com
Ms. Leslie Brown, Weaver Construction Management, Inc., leslie@weavercm.com
Mr. Mark Reasinger, P.E., Plant Engineering Consultants, Inc., mreasinger@planteci.com

cc: Mr. Jerry Miller, Resident Project Representative, GMS, Inc.