

**GMS, INC.**  
CONSULTING ENGINEERS  
611 NORTH WEBER, SUITE 300  
COLORADO SPRINGS, COLORADO 80903-1074

TELEPHONE (719) 475-2935  
TELEFAX (719) 475-2938

EDWARD D. MEYER, P.E.  
ROGER J. SAMS, P.E.  
GREGORY R. WORDEN, P.E.  
THOMAS A. McCLERNAN, P.E.

KEN L. WHITE, P.L.S.  
DAVID R. FRISCH, P.L.S.  
MARK A. MORTON, P.E.  
JASON D. MEYER, P.E.

October 22, 2012

Mr. Wes Weaver, President  
Weaver Construction Management, Inc.  
3679 South Huron Street, Suite 404  
Englewood, CO 80110

*Via Email to: wes@weavercm.com  
No Hard Copy to Follow*

Re: Harold D. Thompson Regional Water Reclamation Facility (HDTRWRF)  
Lower Fountain Metropolitan Sewage Disposal District (LFMSDD)

Dear Wes:

Reference is made to your shop submittal identified as follows:

Submittal No.:	16410-002
Date of Submittal:	October 15, 2012
Title:	Electrical-Operations Building: Panelboard, Dry Type Transformers; Enclosed Circuit Breakers; Safety Switches; LVT
Specification Sections	16410 – Enclosed Switches and Circuit Breakers 16442 – Panelboards 16461 – Low Voltage Transformers
Manufacturer:	Eaton Corporation

The referenced submittal has been stamped "**No Exception Taken**" and "**Make Corrections Noted**".  
No additional information or resubmittal is required on this item. Our comments are as follows:

1. Panelboard OP-H1: **No Exception Taken**
2. Panelboard OP-L1: **No Exception Taken**
3. Transformer TX-OPL1: **No Exception Taken**
4. 400A Fusible Switch: **Make Corrections Noted**
  - a. Revise fuse size from 400A to 250A (FRN-R-250) as specified.
5. Safety Switches, 30A and 60A: **No Exception Taken**

Please call if you should have any questions.

Sincerely,



David R. Frisch, P.L.S.

DRF/kmw

ec (letter only):

Mr. Jim Heckman, Manager, LFMSDD, [lfmanager@lfmsdd.org](mailto:lfmanager@lfmsdd.org)  
Ms. Cindy Murray, Office Manager, Fountain Sanitation District, [fsdistrict@fsd901.org](mailto:fsdistrict@fsd901.org)  
Mr. Jeff Burst, Project Supt., Weaver Construction Management, Inc., [jeff@weavercm.com](mailto:jeff@weavercm.com)  
Mr. John Jacob, Project Mgr., Weaver Construction Management, Inc., [john@weavercm.com](mailto:john@weavercm.com)  
Mr. Adam Roeder, Weaver Construction Management, Inc., [aroeder@weavercm.com](mailto:aroeder@weavercm.com)  
Ms. Leslie Brown, Weaver Construction Management, Inc., [leslie@weavercm.com](mailto:leslie@weavercm.com)  
Mr. Mark Reasinger, P.E., Plant Engineering Consultant, Inc., [mreasinger@planteci.com](mailto:mreasinger@planteci.com)

cc (letter only): Mr. Jerry Miller, Resident Project Representative, GMS, Inc.