

**GMS, INC.**  
CONSULTING ENGINEERS  
611 NORTH WEBER, SUITE 300  
COLORADO SPRINGS, COLORADO 80903-1074

TELEPHONE (719) 475-2935  
TELEFAX (719) 475-2938

EDWARD D. MEYER, P.E.  
ROGER J. SAMS, P.E.  
GREGORY R. WORDEN, P.E.  
THOMAS A. McCLERNAN, P.E.

KEN L. WHITE, P.L.S.  
DAVID R. FRISCH, P.L.S.  
MARK A. MORTON, P.E.  
JASON D. MEYER, P.E.

November 17, 2011

Mr. Wes Weaver, President  
Weaver Construction Management, Inc.  
3679 South Huron Street, Suite 404  
Englewood, CO 80110

***Via Email to: wes@weavergc.com  
No Hard Copy to Follow***

Re: Harold D. Thompson Regional Water Reclamation Facility (HDTRWRF)  
Lower Fountain Metropolitan Sewage Disposal District (LFMSDD)

Dear Wes:

Reference is made to your shop submittal identified as follows:

Submittal No.:	03300-022A
Date of Submittal:	November 2, 2011
Title:	Headworks Building Submittal Letter
Specification Section:	03300 – Cast-In-Place Concrete
Supplier:	Baker Concrete Construction

The referenced submittal has been stamped "**No Exception Taken**". No additional information or resubmittal is required on this item. Our comments are as follows:

1. Mix design A70F, 5" slump for walls, 3" slump for slabs is an acceptable mix design for this use. The use of this concrete mix design is conditioned upon the incorporation of the comments provided in GMS, Inc. response dated August 23, 2011 for Shop Submittal No. 03300-009H.
2. The shop submittal references WGC RFI 18A for the Sika Swell S2 waterstop. Included in the submittal is RFI No. 18 which rejects the use of the Sika Swell product. Please reference RFI 18A when considering the use of this product.

Please call if you should have any questions.

Sincerely,



David R. Frisch, P.L.S.

DRF/kmw

ec (letter only):

Mr. Jim Heckman, Manager, LFMSDD, [lfmanager@lfmsdd.org](mailto:lfmanager@lfmsdd.org)  
Ms. Cindy Murray, Office Manager, Fountain Sanitation District, [fsdistrict@fsd901.org](mailto:fsdistrict@fsd901.org)  
Mr. Jeff Burst, Project Supt., Weaver Construction Management, Inc., [jeff@weavergc.com](mailto:jeff@weavergc.com)  
Mr. John Jacob, Project Mgr., Weaver Construction Management, Inc., [john@weavergc.com](mailto:john@weavergc.com)  
Mr. Tyler Ammerman, Weaver Construction Management, Inc., [tammerman@weavergc.com](mailto:tammerman@weavergc.com)  
Ms. Leslie Brown, Weaver Construction Management, Inc., [leslie@weavergc.com](mailto:leslie@weavergc.com)  
cc: Mr. Jerry Miller, Resident Project Representative, GMS, Inc. (w/attachment)