

GMS, INC.
CONSULTING ENGINEERS
611 NORTH WEBER, SUITE 300
COLORADO SPRINGS, COLORADO 80903-1074

TELEPHONE (719) 475-2935
TELEFAX (719) 475-2938

EDWARD D. MEYER, P.E.
ROGER J. SAMS, P.E.
GREGORY R. WORDEN, P.E.
THOMAS A. McCLENNAN, P.E.

KEN L. WHITE, P.L.S.
DAVID R. FRISCH, P.L.S.
MARK A. MORTON, P.E.
JASON D. MEYER, P.E.

November 17, 2011

Mr. Wes Weaver, President
Weaver Construction Management, Inc.
3679 South Huron Street, Suite 404
Englewood, CO 80110

Via Email to: wes@weavergc.com
No Hard Copy to Follow

Re: Harold D. Thompson Regional Water Reclamation Facility (HDTRWRF)
Lower Fountain Metropolitan Sewage Disposal District (LFMSDD)

Dear Wes:

Reference is made to your shop submittal identified as follows:

Submittal No.:	03300-023A
Date of Submittal:	November 2, 2011
Title:	Pumping and Disinfection Building Submittal Letter
Specification Section:	03300 – Cast-In-Place Concrete
Supplier:	Baker Concrete Construction

The referenced submittal has been stamped "***No Exception Taken***" and "***Make Corrections Noted***".
Our comments are as follows:

1. Mix design A70F, 5" slump for walls, 3" slump for slabs is an acceptable mix design for this use. The use of this concrete mix design is conditioned upon the incorporation of the comments provided in GMS, Inc. response dated August 23, 2011 for Shop Submittal No. 03300-009H.
2. WGC RFI 18 Waterstop – Sika Swell S2: ***Make Corrections Noted***
 - a. The shop submittal, as provided, indicates the reference to RFI 18. We request use of the Sika Swell S2 product be in accordance with RFI **18A** where the use of the product was approved with conditions.

Please call if you should have any questions.

Sincerely,



David R. Frisch, P.L.S.

DRF/kmw

ec (letter only):

Mr. Jim Heckman, Manager, LFMSDD, lfmanager@lfmsdd.org
Ms. Cindy Murray, Office Manager, Fountain Sanitation District, fsdistrict@fsd901.org
Mr. Jeff Burst, Project Supt., Weaver Construction Management, Inc., jeff@weavergc.com
Mr. John Jacob, Project Mgr., Weaver Construction Management, Inc., john@weavergc.com
Mr. Tyler Ammerman, Weaver Construction Management, Inc., tammerman@weavergc.com
Ms. Leslie Brown, Weaver Construction Management, Inc., leslie@weavergc.com

cc: Mr. Jerry Miller, Resident Project Representative, GMS, Inc. (w/attachment)