

## WEAVER CONSTRUCTION MANAGEMENT, INC.

COMMENTS:\_\_\_\_

3679 S. Huron St., Suite 404 Englewood, CO 80110 Phone: (303) 789-4111 FAX: (303) 789-4310

## SUBMITTAL TRANSMITAL

October 26, 2011

•		WGC Submittal No: 11332-001.A
PROJECT:	Harold Thompson Regiona Birdsall Rd. Fountain, CO 80817 Job No. 2908	N WRF
ENGINEER:	GMS, Inc. 611 No. Weber St., #300 Colorado Springs, CO 8090 719-475-2935 Roger Sams	
OWNER:	Lower Fountain Metropolite Sewage Disposal District 901 S. Santa Fe Ave. Fountain, CO 80817 719-382-5303 James Heck	
CONTRACTOR:	WesTech Engineering, Inc 3665 S West Temple Salt Lake, UT 84115 801-265-1000	
SUBJECT: Submit & Control Panels	tal letter addressing commer	nts of review for Cleanwash Screw Wash Presses
SPEC SECTION: 1	11332 - Screening Compacto	pr
PREVIOUS SUBM	ISSION DATES: 9/22/11	
DEVIATIONS FRO	M SPEC:YES _X_ N	10
respect to the means, I	methods, techniques, & safety pre	ewed by Weaver General Construction and approved with cautions & programs incidental thereto. Weaver General ith contracted documents and comprises on deviations
Contractor's Stamp:		Engineer's Stamp:
Date: 10/26/11 Reviewed by: H.C. Myers (X) Reviewed Without Comments () Reviewed With Comments		
ENGINEER'S		



John Jacob Weaver Construction Management David Frisch GMS 25 October 2011

The following are WesTech's comments to Submittals 14555-001 and 11332-001 and the 17 October letters addressing them.

Submittal No. 11332-001

Comments 2 and 3 dealt with the piping configuration with a ninety degree bend to add clearance near the dumpster and adding an additional flange connection to provide and easier removal of a section.

The attached revision "A" of the General Arrangement drawings (21393AB-D101) should address the issues that we discussed with Mr. David Frisch and where contained in the returned submittals.

Channel #2 - the piping has a ninety degree elbow up and the flange was added after the ninety degree elbow back to horizontal.

Channel #1 - the flange was added after the pipe support to allow removal of the section closets to the conveyor without disturbing the support of the discharge pipe run.

Submittal No. 14555-001

Comment 3 was about the discrepancy in our submitted information with 18 rpm on drawing and 16 rpm in cut sheets. That was our oversight – the drawing has been revised to have the 16 rpm inserted. See attached revision "A" of the General Arrangement drawings (21393AB-D101).

Comment 4 had to deal with the calculations. A summary sheet was enclosed two pages before the Enclosure fly leaf page.

- It was not identified in the Table of Contents as Spiral Calculations, which is our mistake.
- It does show the SK3282 gear box meets the torque requirement and a minimum of 1.1kw required power (we supplied a 1.5 hp which meets the 1.1 kw).
- At does have the spiral strength calculation results shown. If a detailed or expanded layout of the program used for these calculations is required I will contact our engineer who did the calculations.

If you have any questions, comments or need additional information, please contact me.

Regards

Jeff Watry

Direct Phone: 801-290-6450

Cell:262-331-3062

email: jwatry@westech-inc.com

An Employee-Owned Company

