

SUBMITTAL TRANSMITAL

December 16, 2011 WGC Submittal No: 13100-002

- PROJECT: Harold Thompson Regional WRF Birdsall Rd. Fountain, CO 80817 Job No. 2908
- ENGINEER: GMS, Inc. 611 No. Weber St., #300 Colorado Springs, CO 80903 719-475-2935 Roger Sams
- OWNER: Lower Fountain Metropolitan Sewage Disposal District 901 S. Santa Fe Ave. Fountain, CO 80817 719-382-5303 James Heckman
- CONTRACTOR: McDade Woodcock, Inc. 7222 Commerce Center Drive, #245 Colorado Springs, CO 80909 719-264-1236

SUBJECT: Lightning Protection for the Secondary Clarifier Complex

SPEC SECTION: 13100

PREVIOUS SUBMISSION DATES:

DEVIATIONS FROM SPEC: ____ YES _X__ NO

CONTRACTOR'S STAMP: This submittal has been reviewed by Weaver General Construction and approved with respect to the means, methods, techniques, & safety precautions & programs incidental thereto. Weaver General Construction also warrants that this submittal complies with contracted documents and comprises on deviations thereto:

Contractor's Stamp:	Engineer's Stamp:
Date: 12/16/11 Reviewed by: H.C. Myers (X) Reviewed Without Comments () Reviewed With Comments	
ENGINEER'S COMMENTS:	

McDade-Woodcock, Inc.

Phone: 719-264-1236 Fax: 719-264-1450

C 80919 Fax: 7

PROJECT: Harold D. Thompson WRF

TO: Weaver General Construction

DATE: 12/14/2011

REF: Electrical Submittal 13100B-001 Lightning Protection (Secondary Clarifier)

ATTN: Wes Weaver

,


WE ARE SENDING:	SUBMITTED FOR:	ACTION TAKEN:
Shop Drawings	Approval	Approved as Submitted
Letter	☐ Your Use	Approved as Noted
Prints	As Requested	Returned After Loan
Change Order	Review and Comment	Resubmit
Plans		🗹 Submit
Samples	SENT VIA:	Returned
Specifications	Attached	Returned for Corrections
Other:	Separate Cover Via	Due Date: 1/4/2012

ITEM PACKAGE SUBMITTAL DRAWING REV. ITEM NO. COPIES DATE DESCRIPTION STATUS

001 1 12/14/2011 Electrical Submittal OUT 13100B-001 Lightning Protection

Lightning Protection (Secondary Clarifier Complex)

Remarks: Electrical Submittal for Review and Approval Via Email Only



CC:



McDADE-WOODCOCK, INC. HAROLD D. THOMPSON RWRF **HEADWORKS BUILDING**

McDADE-WOODCOCK INC. **PROJECT NUMBER - 1402**

ELECTRICAL SUBMITTAL

LIGHTNING PROTECTION

SECONDARY CLARIFIER COMPLEX

13100B-001

CORPORATE

2404 Claremont Ave. NE Albuquerque, NM 87107

Mailing Address P.O. Box 11592 Albuquerque, NM 87192 Ph 505-884-0155

Fax 505-884-6073

DENVER

10700 E. Geddes Avenue Suite 170 Englewood CO 80112 Ph 303-803-1809 Fax 303-803-1818

COLORADO SPRINGS

7222 Commerce Center Drive Suite 245 Colorado Springs, CO 80919

Mailing Address P.O. Box 7349 Colorado Springs, CO 80933

Ph 719-264-1236 Fax 719-264-1450 **Owner:**

Lower Fountain Metropolitan Sewage District 901 S. Santa Fe Avenue Fountain, CO 80817

General Contractor:

Weaver General Construction Co. 3679 S. Huron St. - Suite 404 Englewood, CO 80110

Electrical Contractor:

Engineer:

McDade-Woodcock, Inc. 7222 Commerce Center Dr. #245 Colorado Springs, CO 80919

GMS Inc. 611 N. Weber St., Suite 300 Colorado Springs, CO 80903

MWIEIC.com



McDADE-WOODCOCK, INC.

HAROLD D. THOMPSON RWRF HEADWORKS BUILDING

McDADE-WOODCOCK INC. PROJECT NUMBER - 1402

ELECTRICAL SUBMITTAL

LIGHTNING PROTECTION

SECONDARY CLARIFIER COMPLEX

13100B-001

TABLE OF CONTENTS

TAB 1: Technical Data

CORPORATE

2404 Claremont Ave. NE Albuquerque, NM 87107 Mailing Address P.O. Box 11592 Albuquerque, NM 87192 Ph 505-884-0155 Fax 505-884-6073

DENVER

10700 E. Geddes Avenue Suite 170 Englewood C0 80112 Ph 303-803-1809 Fax 303-803-1818

COLORADO SPRINGS

7222 Commerce Center Drive Suite 245 Colorado Springs, CO 80919

Mailing Address P.O. Box 7349 Colorado Springs, CO 80933

Ph 719-264-1236 Fax 719-264-1450

MWIEIC.com

ELECTRICAL • ROAD & TRAFFIC • INSTRUMENTATION & CONTROL



3788 INTERPARK DRIVE COLORADO SPRINGS, CO 80907

(719) 488-2315 • (303) 762-0282 FAX: (719) 488-3612 WWW.MRLIGHTNING.COM EMAIL: INFO@MRLIGHTNING.COM

PROJECT

SECONDARY CLARIFIER COMPLEX HAROLD D. THOMPSON RWRF FOUNTAIN, COLORADO

SUBMITTAL

SPECIFICATION SECTION 13100 "LIGHTNING PROTECTION"

CONTRACTOR

MCDADE WOODCOCK 7222 COMMERCE CENTER DRIVE, #245 COLORADO SPRINGS, CO 80919 (719) 264-1236 ATTN: PATRICK DANENBERG

LIGHTNING PROTECTION CONTRACTOR

MR. LIGHTNING 3788 INTERPARK DRIVE COLORADO SPRINGS, CO 80907 (719) 488-2315 ATTN: ALLEN SCOTT COREY

STANDARD OF EXCELLENCE











Certification of Lightning Protection Equipment Conformance

East Coast Lightning Equipment, Inc. has been listed with Underwriters Laboratories (UL) as a manufacturer of lightning protection equipment, including lightning conductors, air terminals and fittings since January of 1984. All of the products we sell comply with UL requirements. All products are designed for incorporation into UL Master Labeled lightning protection installations. Our file number with UL is E93753. Our Manufacturer listing mark is 50MO.

East Coast Lightning Equipment, Inc. is a Manufacturer Member of the Lightning Protection Institute (LPI). We are represented on their Board of Directors. We have on staff a certified LPI Master Installer and Systems Designer. All of our products comply with LPI's materials requirements.

Similarly, our products comply with the lightning protection requirements of the National Fire Protection Association as established by NFPA Standard 780.

Through our seats on the Underwriters Laboratory's Industrial Advisory Committee for Lightning Protection and the NFPA's Technical Committee for Lightning Protection Systems we maintain compliance with current code requirements.

Certification of Warranty

East Coast Lightning Equipment, Inc. warrants that our components meet product testing and inspection for quality of workmanship prior to being shipped from our facility. Our components are guaranteed against defects in material and/or workmanship for one year.

Our lightning protection equipment, including lightning conductors, air terminals and fittings are inspected by UL quarterly. Thus assuring compliance with the most current material requirements of the Underwriters Laboratory's (UL), the Lightning Protection Institute (LPI), and the National Fire Protection Association (NFPA).



C2009ECLE.

24 Lanson Drive | Winsted, CT 06098 T 860.379.9072 F 860.379.2046 EM Info@ede.biz WEB w ww.ede.biz

7 Materials

7.1 A lightning protection system shall be made of materials that are resistant to corrosion or shall be acceptably protected against corrosion as specified in the Standard for Lightning Protection Components, UL 96.

7.2 Metals shall not be used in combinations that form electrolytic corrosion (metals that are not galvanically compatible) that accelerates their degradation (corrosion or oxidation) in the presence of moisture. This requirement is applicable to lightning protection system components as well as the surface material on which they are mounted. For example, a combination of copper and aluminum shall not be used. See 7.5 - 7.8. Some examples of metals acceptable for use with copper and aluminum are as follows:

a) Metals acceptable for use with copper:

Nickel

Brass

Tin

Lead

Stainless Steel

Monel

b) Metals acceptable for use with aluminum:

Magnesium

Zinc

Galvanized Steel

Stainless Steel

Lead

Wrought Iron

Galvalume

7.2 revised October 4, 2010

7.3 Deleted October 4, 2010

UL COPYRIGHTED MATERIAL – NOT AUTHORIZED FOR FURTHER REPRODUCTION OR DISTRIBUTION WITHOUT PERMISSION FROM UL 7.4 Lightning conductors subject to mechanical damage or displacement shall be protected with molding or tubing. Metal pipe or tubing used around a conductor shall be bonded to the conductor at both ends of the pipe or tubing. A downspout shall not be used as a protector. See 9.3.5.

7.5 A copper lightning protection component shall not be installed directly on aluminum surfaces or external galvanized steel surfaces. See 7.2.

7.6 An aluminum lightning protection component shall not be installed directly on copper roofing material or other copper surface or below the run off from a copper surface. See 7.2.

7.7 Aluminum components shall not be used where they come into direct contact with earth. Bimetallic fittings shall be used for the connection of aluminum down conductors to copper or copper-clad conductors. Where so used, bimetallic fittings shall not be installed less than 18 inches (460 mm) above earth level. See 7.2.

7.8 Bimetallic fittings shall be used when joining metals that are not galvanically compatible. See 7.2.

7.9 Aluminum conductors and components shall not be:

- a) Embedded in concrete or masonry;
- b) In direct contact with a surface coated with an alkaline base paint; or
- c) Installed in wet locations, for example inside eave troughs or downspouts.

8 Strike Termination Devices

8.1 General

8.1.1 A metal body that is 3/16 inch (4.8 mm) thick or greater that is subject to a direct lightning strike may serve as a strike termination device and shall be connected to the lightning protection system. The connections shall be main-size and provide a two-way path to ground as is required for air terminals.

8.1.2 Strike termination devices shall be installed to provide a zone of protection in accordance with Section 8.2 for each part of a structure that is exposed to direct lightning strikes.


8.1.3 Air terminals are not required for parts of a structure located within a zone of protection.

8.1.4 Strike termination devices that are a permanent part of the structure and that are 3/16 inch (4.8 mm) thick or more shall be connected to the lightning protection system using main-size conductors and a main size bonding plate/connector as described 12.10 and shall have a two-way path to ground as is required for air terminals.

8.1.4 revised October 4, 2010

8.1.5 An air terminal shall be placed not more than 2 feet (610 mm) from the ends of each ridge, edge, or outside corner of roofs. See Figure 8.2.

UL COPYRIGHTED MATERIAL – NOT AUTHORIZED FOR FURTHER REPRODUCTION OR DISTRIBUTION WITHOUT PERMISSION FROM UL




	Get grounded.
64/0-19T	As above with tinned copper strands.
	Exceeds Class II requirements.
STETTIND	653 pounds per thousand feet (972 grams/meter). 211,475 circular mils (107mm ²) of conductivity.
C4/0-19	19 strands of .1055 gauge (2.68mm) concentric lay copper cable
C1/0-19T	As above with tinned copper strands.
	1 05,600 circular mils of conductivity. E xceeds Class II requirments .
61/0-19	19 strands of .0837 gauge (2.13mm) concentric lay copper cable 326 pounds per thousand feet.
C385T	As above with tinned copper strands.
	Exceeds Closs II requirements.
	385 pounds per thousand feet (573 gram/meter). 121,968 circular mils (61.5mm ²) of conductivity.
C 385	28 strands of .066 gauge (1.68mm) rope lay copper cable.
C32 T	As above with tinned copper strands.
632 L	As above with leaded copper strands.
	65,667 circular mile (33mm²) of conductivity. Exceeds Class I requirements.
632	32 strands of 17 (1.15mm) gauge basket weave copper cable. 217 pounds per thousand feet (323 grams/meter).
629T	As above with tinned copper strands.
G29 L	As above with leaded copper strands.
C29	29 strands of 17 gauge (1.15mm) basket weave copper cable. 192 pounds per thousand feet (286 grams/meter). 59,450 circular mils (30mm ²) of conductivity. Exceeds Class requirements.
<u>C14T</u>	As abave with tinned copper strands.
C14	14 strands of 17 gauge (1.15mm) secondary bonding copper cable. 92 pounds per thousand feet (137 grams/meter). 28,729 circular mils (14.5mm²) of conductivity.


<u>Blunt Air Terminals—AT</u>


Class $I - 1/2^{\circ}$ (12.7mm) diameter, threaded base, UL listed. ALUMINUM ATIOAB 1/2" x 10" (12.7mm x 254mm) 1/2" x 12" (12.7mm x 305mm) AT12AB 1/2" x 15" (12.7mm x 381mm) AT15AB 1/2" x 18" (12.7mm x 458mm) AT18AB 1/2" × 24" (12.7mm × 610mm) 1/2" × 36" (12.7mm × 915mm) 1/2" × 48" (12.7mm × 1220mm) AT24AB AT36AB AT48AB **Class II** -5/8" (15.9mm) diameter, threaded base, UL listed. ALUMINUM AT110AB 5/8" x 10" (15.9mm x 254mm) 5/8" x 12" (15.9mm x 305mm) AT112AB 5/8" x 15" (15.9mm x 381mm) AT115AB 5/8" x 18" (15.9mm x 458mm) AT118AB 5/8" x 24" (15.9mm x 610mm) AT124AB 5/8" x 36" (15.9mm x 915mm) AT136AB AT148AB 5/8" x 48" (15.9mm x 1220mm) Claas 1 - 3/8" (9.5mm) diameter, threaded base, UL listed. COPPER AT10CB 3/8" x 10" (9.5mm x 254mm) 3/8" x 12" (9.5mm x 305mm) AT12CB 3/8" x 15" (9.5mm x 381mm) AT15CB 3/8" x 18" (9.5mm x 458mm) AT18CB 3/8" x 24" (9.5mm x 610mm) AT24CB 3/8" × 36" (9.5mm × 915mm) 3/8" × 48" (9.5mm × 1220mm) AT36CB AT48CB Class II -1/2" (12.7mm) diameter, threaded base, UL listed. COPPER AT110CB 1/2" x 10" (12.7mm x 254mm) 1/2" x 12" (12.7mm x 305mm) AT112CB 1/2" × 15" (12.7mm × 381mm) 1/2" × 18" (12.7mm × 458mm) AT115CB AT118CB 1/2" x 24" (12.7mm x 610mm) AT124CB 1/2" × 36" (12.7mm × 915mm) 1/2" × 48" (12.7mm × 1220mm) AT136CB AT148CB Class II -5/8" (15.9mm) diameter, threaded base, UL listed. COPPER 5/8" x 10" (15.9mm x 254mm) AT210CB AT212CB 5/8" x 12" (15.9mm x 395mm) 5/8" x 15" (15.9mm x 381mm) 5/8" x 18" (15.9mm x 458mm) AT215CB AT218CB 5/8" x 24" (15.9mm x 610mm) 5/8" x 36" (15.9mm x 915mm) 5/8" x 48" (15.9mm x 1220mm) AT224CB AT236CB AT248CB All air terminals are available in any length to twelve feet (365.75cm).


Get grounded.

©2009ECLE. 24 Lanson Drive Winsted, CT 06098 T 860.379.9072 F 860.379.2046 EM Info@ede.biz WEB w ww.ede.biz













©2009ECLE. 24 Lanson Drive | Winsted, CT 06098 T 860.379.9072 F 860.379.20


T 860.379.9072 F 860.379.2046 EM info@ede.biz WEB w ww.ede.biz

23





<u>Bimetallic Fittings—BM</u> For Connecting Aluminum and Copper







C2009ECLE. 24 Lanson Drive Winsted, CT 06098 T 860.379.9072 F 860.379.2046 EM Info@ede.biz WEB w ww.ecle.biz









The Lightning Protection Institute

6

1

10

This is to certify that

Bret A. Peifer

being qualified by experience and found upon examination in

Colorado Springs, Colorado to possess advanced knowledge and expert abilities, is a

Master Installer Designer # 1042

of <u>Mr. Lightning</u>. Attest this October Twentieth, Two Thousand Ten.

Houndal Audillo III Executive Director

