



WEAVER CONSTRUCTION MANAGEMENT, INC.
 3679 S. Huron St., Suite 404
 Englewood, CO 80110
 Phone: (303) 789-4111 FAX: (303) 789-4310

SUBMITTAL TRANSMITTAL

November 28, 2011
WCM Submittal No: 02641-002.A

PROJECT: Harold Thompson Regional WRF
 Birdsall Rd.
 Fountain, CO 80817
 Job No. 2908

ENGINEER: GMS, Inc.
 611 No. Weber St., #300
 Colorado Springs, CO 80903
 719-475-2935 Roger Sams

OWNER: Lower Fountain Metropolitan
 Sewage Disposal District
 901 S. Santa Fe Ave.
 Fountain, CO 80817
 719-382-5303 James Heckman

CONTRACTOR: Superior Sales, Inc.
 13301 W 43rd Drive #11
 Golden, CO 80403
 303-279-3600 Jim Warner
 JimWarner@superiorsalesco.com

SUBJECT: Clarification letter to review comments and submittal number correction.

SPEC SECTION: 02641

PREVIOUS SUBMISSION DATES: 11/21/11

DEVIATIONS FROM SPEC: YES NO

CONTRACTOR'S STAMP: This submittal has been reviewed by WCM and approved with respect to the means, methods, techniques, & safety precautions & programs incidental thereto. Weaver General Construction also warrants that this submittal complies with contracted documents and comprises on deviations thereto:

Contractor's Stamp:

Engineer's Stamp:

Date: 11/28/11

Reviewed by: H.C. Myers
 Reviewed Without Comments
 Reviewed With Comments

ENGINEER'S
 COMMENTS: _____



Project: HDTWRF Project

Location: Fountain, CO

Supplier: Superior Sales

Date: 11/28/11

Submittal for: Submittal # correction [02641-002.A](#)

1. In response to GMS comments: The pumper nozzle is 4 ½" and hose nozzles are 2 ½" nominal.
No further action is necessary.