



Weaver

CONSTRUCTION MANAGEMENT

3679 S Huron Street, Suite 404 Englewood, Colorado 80110

Phone: (303) 789-4111 FAX: (303) 789-4310

SUBMITTAL TRANSMITTAL

August 16, 2012

WCM Submittal No: 02641-006.A

PROJECT: **Harold Thompson Regional WRF**
Birdsall Rd.
Fountain, CO 80817
Job No. 2908

ENGINEER: **GMS, Inc.**
611 No. Weber St., #300
Colorado Springs, CO 80903
719-475-2935 Roger Sams

OWNER: **Lower Fountain Metropolitan
Sewage Disposal District**
901 S. Santa Fe Ave.
Fountain, CO 80817
719-382-5303 James Heckman

CONTRACTOR: **Municipal Treatment Equipment , Inc.**
17301 W Colfax Ave, #105
Golden, CO 80401
303-231-9175 Tim Rice

SUBJECT: Response to review comments from August 14, 2012 for the Rotork Electric Actuator

SPEC SECTION: 02641 Valves and Accessories

PREVIOUS SUBMISSION DATES: 7/16/12

DEVIATIONS FROM SPEC: ___ YES x NO

CONTRACTOR'S STAMP: This submittal has been reviewed by Weaver Construction Management and, unless indicated otherwise, has been found to be in conformance with the intent of the contract documents.

Contractor's Stamp:

Date: 8/16/12

Reviewed by: John Jacob

(X) Reviewed Without Comments

() Reviewed With Comments

ENGINEER'S

COMMENTS:

Engineer's Stamp:



17301 W. Colfax Avenue, Unit 105
Golden, CO 80401
(303) 231-9175
(303) 231-0964 fax
www.municipaltreatment.com

8/16/12

TO: Wes Weaver
Weaver Construction Management

PROJECT: Harold D. Thompson Regional Water Reclamation Facility

RE: Dezurik Plug Valves and Rotork Electric Actuators

Response to Engineer's Comments

#3:

a). Actuator is Modulating

b). Actuator is capable of sending 4-20mA signal for valve position indication and accepting 4-20 mA signal for modulating.

NOTE: 4-20 mA signal for valve position will need to be calibrated by the SCADA system to show percent open or closed.

Thank You,
Bob Hoss